



Product Service

CERTIFICATE

No. B 090781 0013 Rev. 00

Holder of Certificate: Ningbo Shihe
New Energy Technology Co., Ltd.
Rongyu Hamlet
Xinpu Town
315322 Cixi City, Zhejiang
PEOPLE'S REPUBLIC OF CHINA

Certification Mark:



Product: Electric Cables
Electric cables for photovoltaic systems
with a voltage rating of 1,5 kV DC

Model(s): 62930 IEC 131 1×4mm²

Parameters:

Rated Voltage:	DC 1.5 kV (between conductors and between conductor and earth) AC U0/U: 1.0/1.0 kV
Application Class:	A
Protection Class:	II
Ambient Temperature:	-40°C~+90°C
Max. Temperature at conductor:	120°C

Tested according to: IEC 62930(ed.1)

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 704072131901-00
Valid until: 2027-01-06

Date, 2022-01-07

(Yaqun Alex Liu)

ZERTIFIKAT ◆ CERTIFICATE ◆ 認證證書 ◆ CERTIFICADO ◆ CERTIFICAT